



Specification: Stand-alone self-contained emergency LED downlight. Constant emergency light (1.5W/150Im & 3W/270Im) for 3 hours. Low stand-by power consumption (0.5W). Self-test versions and remote controls available. Lithium battery integrated. Non-maintained configuration. Ceiling recessed mounting. Suitable for open area and corridor indoor applications.



* Self-test only available on AST and PST versions

MAX Emergency Downlight

Key Features

- Non-maintained configuration
- High lumen output in emergency mode
- Fast battery re-charge (8 hrs)*
- Low stand-by power consumption (0.5 W)
- Open area, corridor and spot lens options
- Remote control available
- * First battery charge takes up to 16 hours

Part number	Description	Testing facility	Remote control part number *	Operating temperature	Net weight
DLA1.5-OA2-MT	Recessed LED downlight NM 1.5W 150Im open area MT	Manual Test (MT)	ARC		
DLA1.5-OA2-AST	Recessed LED downlight NM 1.5W 150Im open area Self Test AST	Advance Self-Test (AST)	ARC		
DLA1.5-OA2-PST	Recessed LED downlight NM 1.5W 150Im open area Self Test PST	Programmable Self-Test (PST)	PRC		0.001
DLA1.5-C-MT	Recessed LED downlight NM 1.5W 140Im corridor MT	Manual Test (MT)	ARC		0.20 kg
DLA1.5-C-AST	Recessed LED downlight NM 1.5W 140Im corridor Self Test AST	ARC			
DLA1.5-C-PST	Recessed LED downlight NM 1.5W 140Im corridor Self Test PST	PRC			
DLA3-S45-MT	Recessed LED downlight NM 3W 270lm 45° beam MT	ARC			
DLA3-S45-AST	Recessed LED downlight NM 3W 270Im 45° beam Self Test AST	0°C ~ 40°C			
DLA3-S45-PST	Recessed LED downlight NM 3W 270Im 45° beam Self Test PST	PRC			
DLA3-OA1-MT	Recessed LED downlight NM 3W 270Im open area MT	Manual Test (MT)	ARC		0.25 kg
DLA3-OA1-AST	Recessed LED downlight NM 3W 270Im open area Self Test AST	Advance Self-Test (AST)	ARC		
DLA3-OA1-PST	Recessed LED downlight NM 3W 270Im open area Self Test PST	Programmable Self-Test (PST)	PRC		
DLA3-OA2-MT	Recessed LED downlight NM 3W 270Im open area High Ceiling MT	Manual Test (MT)	ARC		
DLA3-OA2-AST	Recessed LED downlight NM 3W 270Im open area Self Test High Ceiling AST				
DLA3-OA2-PST	Recessed LED downlight NM 3W 270Im open area Self Test High Ceiling PST	Programmable Self-Test (PST)	PRC		

* Advance Remote Control (ARC) allows the accredited installer to carry out functional tests and/or full duration tests at any time and to check system's status. Please refer to ARC's user guide. In addition to ARC functions the Programmable Remote Control (PRC) allows the accredited installer to programme the testing schedule of each emergency luminaire. Please refer to PRC's user guide.

Installation Notes

- Recessed ceiling mount
- IP54 rating front face only
- Terminal block takes wires up to 2 x 1.5mm²



Technical information	chnical information 1.5W 3W Materials		Materials	1.5W	3W			
Input voltage/frequency	220-240V AC 50Hz		Luminaire housing	Polyca	Polycarbonate			
Power consumption			Luminaire lens	Polyca	Polycarbonate			
Maintained	N.A.		Luminaire bracket	N	N.A.			
Non-maintained	3W(Max.*)	6W(Max.*)	Luminaire legend	N	N.A.			
Non-maintainea	0.5W(standby)	0.5W(standby)	Luminaire screws	Nicke	Nickel Steel			
Lumen output			Finish	N	Matt			
On mains voltage	N.A.		Colour	W	White			
On emergency mode	150lm	270lm	Pottom tuno	Li-lon 3.6V	Li-lon 3.6V			
LEDs Lifetime (L-70)	50,000h		Battery type	2500mAh	5000mAh			
Discharge duration	3hr							
Wh (non-maintained standby)	0.5		Logistic information					
o l 1 <i>(</i> 1	up to 8hrs (first charge up to 16hrs)		Product dimensions (L x W x D)mm	Head:ø60x29.8	Head:ø60x29.8 Body:230x82x4			
Charge duration			Product Net weight (Kg)	0.20Kg	0.20Kg / 0.25Kg			
Test facility	MT, AST, PST		Box dimensions (L x W x D)mm	242 x 95	242 x 95 x 44 mm			
	IP54 (Front) IP20 (Back&LED driver)		Gross weight (Kg)	0.28Kg	0.28Kg / 0.32Kg			
IP rating			Quantity of outer carton	42 pcs				
IK rating	ating IK06		Outer carton dimensions(L x W x D)mm	500 x 318	500 x 318 x 315 mm			
Insulation class	I		Outer carton gross weight (Kg) 12.20Kg / 14.10					
Operation temp.	0~	-40°C	Quantity per Euro pallet (1200 x 800)	105	1050 pcs			
Storage temp.	0~	-50°C	Pallet weight (Kg)	10	10 Kg			

Light Source		Certification				
Brand	Luminus	Safety standard	BS EN 60598-2-22			
Quantity	1 pcs	Certified by	LIA			
ССТ	4000K	CE mark	Yes			
CRI	>80	Factory QMS	ISO9001			

* Power consumption only during charging mode

TESTING FACILITIES

MT (Manual Test)	This luminaire needs to be tested by a competent person according to BS EN 50172:2004. This luminaire can be used in conjunction with the Advanced Remote Control (ARC). ARC is an optional tool that adds new features to AST and MT emergency luminaires. If functional test or full duration test is initiated via ARC the MT luminaire will automatically switch to mains mode after the functional or full duration test is completed.
AST (Advanced Self-Test)	This is a self-test luminaire. Functional test is carried out automatically once a week and runs for 30 seconds. Full duration test is carried out automatically every 52 weeks. First full duration test is carried out automatically within the first 4 weeks after the luminaire being connected to mains voltage. This luminaire can be used in conjunction with the Advanced Remote Control (ARC). ARC is an optional tool that adds extra features to AST emergency luminaires. Please refer to the ARC's user guide.
PST (Programmable Self-Test)	This is a programmable self-test luminaire. It must be used in conjunction with a Programmable Remote Control (PRC). Please refer to PRC's user guide.



SPACING TABLE

				Anti-panic 0.5 lux			Escape Route 1 lux				
Photometric curve	Model Number	Mounting height (m)	Lux level directly under	∄ ↔ Transverse to Wall	Transverse to Transverse	Axial to Axial	Axial to Wall	Transverse to Wall	Transverse to Transverse	Axial to Axial	Axial to Wall
		2	6.2	3.8	8.1	8.1	3.8	3.6	7.6	7.6	3.5
		2.5	5.1	4.6	9.8	9.8	4.5	4.1	9.1	9.1	4.0
V [] be or three or an interval database	DLA1.5-OA2	3	3.9	5.2	11.3	11.3	5.2	4.5	10.3	10.4	4.4
w the second sec		3.5	2.7	5.7	12.7	12.8	5.7	4.2	11.3	11.3	4.2
	Open Area	4	1.6	6.1	14.0	14.1	6.1	2.8	11.3	11.5	2.8
	lens (125°)	4.5	1.3	6.5	15.1	15.2	6.4	-	8.3	8.5	-
		5	1.1	5.9	16.1	16.1	5.9	-	7.7	7.8	-
		5.5	0.9	4.4	16.3	16.6	4.6	-	6.8	7.0	-
		6	0.7	-	12.9	13.5	-	-	1.0 4.7	- 12.1	-
		2 2.5	10.1	-	-		-	1.9 2.0	5.1		5.2 5.7
		2.5	8.2 6.3	-	-	-	-	2.0	5.4	13.7	5.7 6.0
T [1] biensily chelleden	DLA1.5-C	-	4.4	-		-	-	2.0	5.6	14.9	4.6
	Corridor	3.5 4	4.4 2.5		-			1.8	5.0	16.1 15.6	4.0
	lens	4.5	4.4	-	-	-	-	1.6	5.7	15.0	4.2 3.8
	(145°x75°)	4.5 5	3.3	-	-	-	-	-	5.6	13.1	3.0 -
4F1	(/	5 5.5	2.2	-	-	-	-	-	5.3	13.1	-
		5.5 6	1.1			-	-	-	4.5	12.0	
		2	10.9	-	- 8.3	8.3	4.0	3.8	8.0	8.0	- 3.7
		2.5	8.3	4.0 4.9	10.1	10.2	4.0	4.5	9.6	9.6	3.7 4.4
V[1] Kernely distribution [7] V V V V V V V V V V V V V V V V V V V		2.5	6.4	4.9 5.6	11.9	11.9	5.5	5.1	11.1	9.0	4.4
	DLA3-OA2 Open Area lens (125°)	3.5	4.6	6.3	13.5	13.5	6.2	5.6	12.5	12.5	5.4
7		4	2.7	7.0	15.0	15.0	6.7	6.0	13.7	12.5	5.9
		4.5	2.7	7.5	16.4	16.4	7.3	6.1	14.7	14.7	5.9
No the second se		4.5	2.4	7.9	17.8	17.8	7.7	5.4	15.6	14.7	5.4
	DLA3-OA1 Open Area lens (155°)	5.5	1.6	8.3	19.0	19.0	8.2	3.7	15.4	15.6	3.7
		6	1.0	8.3	20.1	20.0	8.5	-	10.9	11.4	-
		2	6.2	5.2	12.1	12.0	5.1	4.6	10.7	10.6	4.5
		2.5	5.0	6.0	14.0	13.8	5.9	5.2	12.3	12.1	4.9
V(7) INF INF INF INF Infently clicks for		3	3.9	6.7	15.7	15.5	6.5	5.4	13.7	13.4	5.0
		3.5	2.7	7.3	17.3	20.0	6.9	3.9	14.8	14.3	4.0
		4	1.5	7.5	18.7	18.4	7.1	1.5	14.0	14.1	1.5
		4.5	1.3	7.5	20.0	19.4	6.7	-	11.8	11.4	-
we we set up to set we held		5	1.1	5.3	20.9	20.2	5.5	-	9.9	9.7	-
		5.5	0.9	2.5	20.2	20.2	4.7	-	-	-	-
		6	0.7	-	18.2	18.4	-	-	-	-	-
		2	161.0	1.1	2.3	2.4	1.1	1.1	2.3	2.4	1.1
	DLA3-S45 45° Spot lens (45°)	2.5	130.8	1.4	2.9	3.0	1.4	1.4	2.9	3.0	1.4
VTT BY THE REPORT OF THE REPOR		3	100.7	1.7	3.5	3.6	1.7	1.7	3.5	3.6	1.7
		3.5	70.5	2.0	4.0	4.2	2.0	2.0	4.0	4.1	2.0
1		4	40.3	2.3	4.6	4.8	2.3	2.2	4.6	4.6	2.2
		4.5	34.7	2.5	5.2	5.4	2.6	2.5	5.1	5.1	2.5
		5	29.1	2.8	5.8	5.8	2.8	2.7	5.7	5.7	2.8
		5.5	23.5	3.1	6.3	6.3	3.1	2.9	6.2	6.2	3.0
		6	17.9	3.3	6.9	6.9	3.4	3.2	6.7	6.7	3.2
		6.5	15.0	3.6	7.4	7.4	3.6	3.4	7.2	7.2	3.4
		7	12.2	3.8	7.9	8.0	3.9	3.5	7.7	7.7	3.6